

Energy Consumption and Greenhouse Gas Emissions Reporting - for 2017

Confirm consecutive 12-mth period (mth-yr to mth-yr)	Sept/2017 - Aug/2018
Sector	School Board
Agency Sub-sector	School Board
Organization Name	Dufferin Peel Catholic District School Board

Operation Name	Operation Type	Address	City	Postal Code	Total Floor Area	Unit	Avg hrs/wk	Swimming Pool (Yes/No)	Number of Portables	Electricity Quantity	Electricity Unit	Natural Gas Quantity	Natural Gas Unit	GHG Emissions (Kg)	Energy Intensity (ekWh/sqft)	Comments
All Saints Sep School	School	4105 Colonial Drive	Mississauga	L5L 4E8	55,809.07	Square feet	80	No	0	373,362.31677	kWh	62,101.95873	Cubic Meter	123,870	18.52	
Archbishop Romero (North Campus Gillingham)	School	40 Gillingham Drive	Brampton	L6X 4X7	3,003.13	Square feet	80	No	0	56,234.91223	kWh	6,752.20742	Cubic Meter	13,739	42.62	
Archbishop Romero - Blessed Trinity Catholic Centre for Learning	School	2495 Credit Valley Drive	Mississauga	L5M 4G8	39,030.00	Square feet	80	No	0	421,395.28918	kWh	7,495.85834	Cubic Meter	21,461	12.84	
Ascension of Our Lord	School	7640 Anaka Drive	Mississauga	L4T 3H7	121,544.00	Square feet	80	No	8	1,135,496.55176	kWh	129,229.10153	Cubic Meter	263,966	20.64	A water source heat pump system, approx. 80% school area.
Bishop Francis Allen	School	325 McMurray Avenue South	Brampton	L6Y 1Z4	38,084.29	Square feet	80	No	9	212,609.28711	kWh	32,894.81383	Cubic Meter	65,870	14.76	
Bishop Scalabrini Sep 5	School	325 Central Parkway West	Mississauga	L5B 3J5	43,522.77	Square feet	80	No	4	428,290.86084	kWh	51,210.65263	Cubic Meter	104,229	22.35	
Brian J. Fleming Adult Learning Centre	School	870 Queen Street West	Mississauga	L5H 4G1	33,361.12	Square feet	60	No	1	355,704.29059	kWh	36,633.82427	Cubic Meter	75,414	22.33	
Canadian Martyrs Sep 5	School	1185 Mississauga Valley Boulevard	Mississauga	L5A 3R7	50,092.00	Square feet	80	No	0	193,104.58881	kWh	36,117.08232	Cubic Meter	71,624	11.52	
Cardinal Ambrozic Catholic Secondary School	School	10 Castle Oaks Crossing	Brampton	L6P 3A2	174,143.00	Square feet	80	No	7	1,733,165.00000	kWh	88,571.47306	Cubic Meter	197,436	15.36	A water source heat pump system, approx. 80% school area.
Cardinal Leger SS	School	75 Mary Street	Brampton	L6W 3K5	162,568.40	Square feet	80	No	6	1,410,354.00000	kWh	126,259.97280	Cubic Meter	263,107	16.93	Water-source heat pump, approx. 80% school area air conditioned.
Cardinal Newman Catholic S	School	698 Balmoral Drive	Brampton	L6T 1Z1	63,318.00	Square feet	80	No	0	362,294.99780	kWh	101,949.48428	Cubic Meter	199,015	22.83	
Catholic Education Centre Admin Building	Administrative office	40 Matheson Blvd W	Mississauga	L5R 1C5	95,335.95	Square feet	60	No	0	1,593,577.24121	kWh	74,521.61688	Cubic Meter	168,458	25.02	A chiller-cooling tower system.
Christ The King Sep 5	School	3240 Garthwood Road	Mississauga	L5L 5A3	51,268.50	Square feet	80	No	0	308,688.27100	kWh	45,437.46628	Cubic Meter	91,245	15.44	
Corpus Christi Sep 5	School	4155 Elora Drive	Mississauga	L5B 3N4	36,887.92	Square feet	80	No	0	228,735.55518	kWh	31,325.16474	Cubic Meter	63,181	15.23	
Divine Mercy	School	2840 Duncairn Drive	Mississauga	L5M 5C6	68,221.66	Square feet	80	No	0	550,645.01270	kWh	69,930.08880	Cubic Meter	141,737	18.97	
Father C W Sullivan S	School	62 Seaborn Road	Brampton	L6V 2C1	35,472.42	Square feet	80	No	10	178,466.81299	kWh	54,828.59547	Cubic Meter	106,748	21.46	
Father Clair Tipping	School	25 Mountainberry Road	Brampton	L6R 1J3	51,075.00	Square feet	80	No	0	471,593.99969	kWh	75,501.00000	Cubic Meter	150,902	24.94	
Father Daniel Zanon	School	450 Hillcrest Avenue	Mississauga	L5B 4J3	51,774.41	Square feet	80	No	0	430,487.88318	kWh	59,413.01160	Cubic Meter	119,774	20.51	An air cooled "Carrier" chiller.
Father Francis McSpirtt	School	55 Lexington Road	Brampton	L6P 2B1	57,415.22	Square feet	80	No	3	481,415.99695	kWh	52,742.47634	Cubic Meter	108,044	18.15	A water source heat pump system, approx. 80% school area.
Father Michael Goetz	School	330 Central Parkway	Mississauga	L5B 3K6	197,130.30	Square feet	80	No	0	1,356,026.58789	kWh	169,582.96506	Cubic Meter	344,075	16.02	A water source heat pump system (2001 Addition only), approx. 20% school area. A chiller-cooling tower system for the original school, 80% area.
Fun School Day Care (St. Mary-Mississauga)	School	44 Port Street West	Mississauga	L5H 1C9	7,997.59	Square feet	60	No	0	47,154.47073	kWh	16,195.23516	Cubic Meter	31,435	27.42	
Georges Vanier Sep 5	School	28 Finchgate Boulevard	Brampton	L6T 3H9	34,418.00	Square feet	80	No	0	130,171.99933	kWh	49,816.22169	Cubic Meter	96,436	19.16	
Good Shepherd	School	28 Red River Drive	Brampton	L6R 2H9	62,882.77	Square feet	80	No	0	553,605.00000	kWh	53,652.40427	Cubic Meter	111,013	17.87	An air cooled water chiller ("York").
Guardian Angels	School	62 Heatherdale Drive	Brampton	L7A 2H4	62,589.42	Square feet	80	No	5	671,413.00000	kWh	89,049.82634	Cubic Meter	179,974	25.85	A water source heat pump system, approx. 80% school area.
Holy Cross Sep 5	School	3615 Morning Star Drive	Mississauga	L4T 1Y4	51,962.00	Square feet	80	No	14	326,439.92188	kWh	69,924.22898	Cubic Meter	137,847	20.58	

Holy Family	School	61 Allen Drive	Bolton	L7E 1P7	50,072.00	Square feet	80	No	2	521,880.00000	kWh	36,733.16092	Cubic Meter	78,476	18.22	A water source heat pump system, approx. 80% school area.
Holy Name of Mary (Glenvale Campus)	School	115 Glenvale Boulevard	Brampton	L6S 3J7	83,832.48	Square feet	80	No	18	840,102.99731	kWh	32,491.93242	Cubic Meter	75,962	14.14	
Holy Spirit	School	25 Bloomsbury Avenue	Brampton	L6P 1W9	58,977.00	Square feet	80	No	0	474,080.00000	kWh	46,098.91734	Cubic Meter	95,356	16.35	A water source heat pump system, approx. 80% school area.
Iona SS	School	2170 South Sheridan Way	Mississauga	L5J 2M4	132,492.00	Square feet	80	No	16	1,002,382.84570	kWh	72,654.31049	Cubic Meter	154,701	13.39	Ground Source Heat Pump system, serving approx. 80% school area.
John Cabot Catholic (Replacement)	School	635 Willowbank Trail	Mississauga	L4W 3L6	124,054.10	Square feet	80	No	0	1,325,651.53369	kWh	66,648.76805	Cubic Meter	148,939	16.40	A water source heat pump system, approx. 80% school area.
Keaton Centre	Administrative office	5685 Keaton Crescent	Mississauga	LSR 3H5	39,998.69	Square feet	60	No	0	343,521.63342	kWh	60,276.54078	Cubic Meter	119,903	24.60	Rooftop units for the office areas only.
Lester B Pearson S	School	140 Howden Blvd.	Brampton	L6S 2G1	40,681.00	Square feet	80	No	0	320,998.00000	kWh	19,542.76544	Cubic Meter	42,501	13.00	
Loyola Catholic (Replacement)	School	4010 Sladeview Cres	Mississauga	LSL 6B1	142,159.00	Square feet	80	No	0	1,262,255.30737	kWh	59,042.06150	Cubic Meter	133,461	13.29	A water source heat pump system, approx. 80% school area.
Mary Fix Catholic S	School	486 Paisley Boulevard West	Mississauga	LSB 2M4	41,030.36	Square feet	80	No	11	202,023.35352	kWh	35,579.57845	Cubic Meter	70,762	14.14	
McLaughlin Village ESL Centre	School	499 Ray Lawson Blvd	Brampton	L6Y 0N2	2,350.00	Square feet	80	No	0	13,971.33325	kWh	2,540.52205	Cubic Meter	5,045	17.43	
Metropolitan Andrei Sep S	School	515 Mississauga Valley Boulevard	Mississauga	LSA 3G6	68,302.00	Square feet	80	No	9	296,743.22339	kWh	80,337.35436	Cubic Meter	157,021	16.85	
Notre Dame	School	2 Notre Dame Avenue	Brampton	L6Z 4L5	184,575.20	Square feet	80	No	16	1,504,169.00000	kWh	150,144.99619	Cubic Meter	309,887	16.79	A chiller-cooling tower system.
Our Lady of Fatima (1)	School	39 Sunset Boulevard	Brampton	L6X 1X1	49,012.00	Square feet	80	No	0	632,889.00000	kWh			10,948	12.91	100% electric heating.
Our Lady of Good Voyage Sep S	School	5850 Rivergrove Avenue	Mississauga	LSM 4W2	51,526.84	Square feet	80	No	0	377,901.94775	kWh	14,554.61782	Cubic Meter	34,054	10.34	
Our Lady of Lourdes	School	25 Mount Royal Circle	Brampton	L6P 1W3	50,816.42	Square feet	80	No	0	610,183.99969	kWh	33,375.80326	Cubic Meter	73,656	18.99	
Our Lady of Mercy	School	5820 Glen Erin Drive	Mississauga	LSM 5J9	48,687.00	Square feet	80	No	0	468,671.71680	kWh	20,012.50637	Cubic Meter	45,943	13.99	
Our Lady of Mount Carmel SS	School	3700 Trelawny Circle	Mississauga	LSN 5J7	202,676.00	Square feet	80	No	16	3,305,854.19222	kWh	162,400.51394	Cubic Meter	364,223	24.83	A water source heat pump system (2002 Addition only), approx. 15% school area. A chiller-cooling tower system for original school, 85% area.
Our Lady of Peace Sep S	School	15 Fincham Avenue	Brampton	L6X 3V2	52,964.00	Square feet	80	No	3	323,409.02319	kWh	45,189.22813	Cubic Meter	91,030	15.17	
Our Lady of Providence ES	School	35 Black Oak Drive	Brampton	L6R 1B9	67,877.22	Square feet	80	No	0	439,121.99792	kWh	63,698.00815	Cubic Meter	128,025	16.44	
Pauline Vanier Catholic E S	School	56 Oaklea Boulevard	Brampton	L6Y 4W7	54,142.47	Square feet	80	No	0	245,735.99939	kWh	50,219.45275	Cubic Meter	99,197	14.40	
Philip Pocock Catholic SS	School	4555 Tomken Road	Mississauga	L4W 1J9	192,154.60	Square feet	80	No	5	1,886,477.00000	kWh	75,991.05844	Cubic Meter	176,303	14.02	Ground Source Heat Pump system, serving approx. 80% school area.
Queen of Heaven Sep S	School	1198 Alexandra Avenue	Mississauga	LS E 2A5	52,786.21	Square feet	80	No	0	389,349.46252	kWh	24,916.13809	Cubic Meter	53,842	12.39	A water source heat pump system, approx. 80% school area.
Robert F. Hall Catholic SS	School	6500 Old Church Road	Caledon	L7C 0H3	167,843.00	Square feet	80	No	4	1,799,005.00000	kWh	43,955.63000	Cubic Meter	114,223	13.50	Ground Source Heat Pump system, serving approx. 80% school area
Sacred Heart Sep S	School	24 Kerwood Place	Brampton	L6Z 1Y1	34,703.89	Square feet	80	No	6	161,897.99997	kWh	38,524.12118	Cubic Meter	75,635	16.46	
San Lorenzo Ruiz	School	100 Barondale Drive	Mississauga	L4Z 3R1	60,428.59	Square feet	80	No	0	606,260.75391	kWh	79,423.24264	Cubic Meter	160,647	24.00	
Silvercreek Outdoor Centre	School	13500 Fallbrook Trail	Georgetown	N0B 1H0	3,944.00	Square feet	80	No	1	87,729.64185	kWh			1,518	22.24	100% electric heating
St Teresa of Calcutta	School	1120 Runningbrook Drive	Mississauga	L4Y 2T2	30,587.00	Square feet	80	No	0	250,689.43286	kWh	29,318.78305	Cubic Meter	59,767	18.38	
St. Agnes Sep S	School	103 Richvale Drive South	Brampton	L6Z 4G6	50,913.30	Square feet	80	No	0	322,344.99945	kWh	42,288.82175	Cubic Meter	85,528	15.16	
St. Aidan Catholic	School	34 Buick Boulevard	Brampton	L7A 3B9	45,808.49	Square feet	80	No	5	477,524.00000	kWh	22,855.80223	Cubic Meter	51,472	15.73	A water source heat pump system, approx. 80% school area.
St. Albert of Jerusalem	School	7185 Rosehurst Drive	Mississauga	LSN 7G6	76,748.00	Square feet	80	No	0	510,372.28503	kWh	73,933.26225	Cubic Meter	148,609	16.89	

St. Alfred Sep S	School	3341 Havenwood Drive	Mississauga	L4X 2M2	48,276.14	Square feet	80	No	0	202,591.23389	kWh	59,817.02110	Cubic Meter	116,596	17.36	
St. Aloysius Gonzaga	School	2800 Erin Centre Boulevard	Mississauga	LSM 6R5	194,516.00	Square feet	80	Yes	0	2,245,788.00000	kWh	212,688.60000	Cubic Meter	440,962	23.17	1. Water source heat pump system, approx. 80% floor area. 2. The Bldg houses the School, a public library and a community recreational centre. 3. two swimming pools: A - 3,600 sq.ft.; B - 670 sq.ft., heating source - gas boiler.
St. Alphonsa Catholic ES	School	60 Olivia Marie Rd	Brampton	L6Y 0M4	57,028.00	Square feet	80	No	0	368,876.00000	kWh	30,208.00000	Cubic Meter	63,493	12.10	New school opened in September 2016. A water source heat pump system, approx. 80% area air conditioned.
St. Andre Bessette CES	School	25 Riverstone Drive	Brampton	L6P 2V7	55,565.00	Square feet	80	No	0	421,996.00000	kWh	40,807.22787	Cubic Meter	84,451	15.40	A water source heat pump system, approx. 80% school area.
St. Andrew Sep. S	School	50 Meadow Drive	Orangeville	L9W 4C8	55,549.30	Square feet	80	No	2	497,735.47137	kWh	83,760.28154	Cubic Meter	166,969	24.99	A water source heat pump system for 2007 Addition only, approx.30% school area.
St. Angela Merici	School	83 Edenbrook Hill Drive	Brampton	L7A 2N7	60,364.01	Square feet	80	No	0	546,583.00000	kWh	40,079.83088	Cubic Meter	85,231	16.11	A water source heat pump system, approx.80% school area.
St. Anne Sep S	School	124 Vodden Street	Brampton	L6V 1M5	54,768.34	Square feet	80	No	9	317,641.38208	kWh	80,200.25883	Cubic Meter	157,123	21.36	6 Rooftop HVAC units for cooling
St. Anthony (Replacement)	School	950 North Park Drive	Brampton	L6S 3L5	41,925.43	Square feet	80	No	0	387,036.99963	kWh	29,512.67160	Cubic Meter	62,492	16.71	A water source heat pump system, approx. 80% school area.
St. Augustine SS	School	27 Drinkwater Road	Brampton	L6Y 4T6	188,164.40	Square feet	80	No	3	1,769,297.00000	kWh	61,610.18823	Cubic Meter	147,087	12.88	Ground Source Heat Pump system, serving 60% area - Gym and 2002 Addition not covered.
St. Barbara	School	1455 Samuelson Circle	Mississauga	LSN 7Z2	62,775.12	Square feet	80	No	0	572,139.43701	kWh	25,494.63352	Cubic Meter	58,098	13.43	A water source heat pump system, approx. 80% area.
St. Basil	School	4235 Golden Orchard Drive	Mississauga	L4W 3G1	38,773.18	Square feet	80	No	9	180,401.65454	kWh	30,879.28463	Cubic Meter	61,502	13.12	
St. Benedict	School	345 Blind Line, R.R.# 4	Orangeville	L9W 4X1	46,835.00	Square feet	80	No	1	449,721.28485	kWh	36,115.14760	Cubic Meter	76,060	17.80	
St. Bernadette E S	School	1060 White Clover Way	Mississauga	LSV 1G7	57,995.95	Square feet	80	No	0	301,558.45947	kWh	43,097.63280	Cubic Meter	86,698	13.10	
St. Bernard of Clairvaux Catholic	School	3345 Escada Drive	Mississauga	LSM 7V5	69,349.00	Square feet	80	No	2	494,615.87793	kWh	49,161.46875	Cubic Meter	101,502	14.67	A water source heat pump system, approx. 80% area.
St. Bonaventure Catholic	School	35 McCrimmon Drive	Brampton	L7A 2Z5	48,919.00	Square feet	80	No	0	481,488.00000	kWh	5,416.61446	Cubic Meter	18,570	11.02	A water source heat pump system, approx. 80% area.
St. Brigid Sep S	School	81 Torrence Woods	Brampton	L6Y 2X4	44,293.49	Square feet	80	No	0	396,963.66528	kWh	78,892.52034	Cubic Meter	156,023	27.89	
St. Catherine of Siena	School	2350 Hurontario Street South	Mississauga	LSB 1N1	57,113.31	Square feet	80	No	0	401,725.74023	kWh	25,028.28203	Cubic Meter	54,268	11.69	A water source heat pump system, approx. 80% school area.
St. Cecilia- shared	School	10 Brickyard Way	Brampton	L6V 4L5	47,028.00	Square feet	80	No	0	281,321.50000	kWh	58,275.50000	Cubic Meter	115,044	19.15	
St. Charles Garnier	School	4233 Central Parkway East	Mississauga	L4Z 1M7	31,916.56	Square feet	80	No	9	208,365.95996	kWh	44,590.85490	Cubic Meter	87,909	21.38	
St. Christopher Sep S	School	1195 Clarkson Road North	Mississauga	LSJ 2W1	51,534.36	Square feet	80	No	2	264,765.53149	kWh	88,681.14102	Cubic Meter	172,243	23.43	
St. Clare Sep S	School	4140 Glen Erin Drive	Mississauga	LSL 2Z3	36,719.00	Square feet	80	No	0	196,352.21582	kWh	40,485.15845	Cubic Meter	79,939	17.07	
St. Cornelius S	School	16066 Innis Lake Road	Caledon	L7C 2Z2	55,219.38	Square feet	80	No	3	407,327.99939	kWh	67,520.27937	Cubic Meter	134,702	20.37	
St. Daniel Comboni Catholic ES	School	120 Veterans Drive	Brampton	L7A 3Z7	60,320.00	Square feet	80	No	0	253,239.00000	kWh	48,587.00000	Cubic Meter	96,240	12.76	Rooftop HVAC units, 80% school area airconditioned. New school opened in September 2017.
St. David of Wales Sep S	School	4200 Beacon Lane	Mississauga	L5C 3V9	55,240.39	Square feet	80	No	0	610,969.40283	kWh	14,471.79535	Cubic Meter	37,929	13.84	
St. Dominic Sep S	School	515 Hartsdale Avenue	Mississauga	LSG 2G7	29,447.34	Square feet	80	No	5	237,259.32080	kWh	33,117.14552	Cubic Meter	66,716	20.01	
St. Dunstan ES - Closed 09/2017	School	1525 Cuthbert Avenue	Mississauga	LSM 3R6	46,155.65	Square feet	80	No	0	170,770.46948	kWh	38,624.27686	Cubic Meter	75,978	12.59	
St. Edith Stein E S	School	6234 Osprey Boulevard	Mississauga	LSN 5V5	59,352.20	Square feet	80	No	0	301,283.87592	kWh	52,447.15799	Cubic Meter	104,370	14.47	
St. Edmund Campion	School	275 Brisdale Drive	Brampton	L7A 3C7	215,327.60	Square feet	80	No	16	2,064,017.00000	kWh	76,265.99712	Cubic Meter	179,894	13.35	A water source heat pump system, approx. 80% school area.
St. Edmund ES	School	1250 Melton Drive	Mississauga	L4Y 1L5	36,016.57	Square feet	80	No	3	256,848.84106	kWh	40,363.87515	Cubic Meter	80,756	19.04	

St. Elizabeth Seton ES	School	6133 Glen Erin Drive	Mississauga	LSN 2T7	39,283.89	Square feet	80	No	16	247,450.62451	kWh	28,274.65072	Cubic Meter	57,737	13.95	
St. Faustina	School	3420 McDowell Drive	Mississauga	LSM 6R7	71,942.73	Square feet	80	No	2	899,199.77295	kWh	170,836.36336	Cubic Meter	338,542	37.74	A water source heat pump system, approx. 80% school area.
St. Francis of Assisi Sep S	School	2480 Thorn Lodge Drive	Mississauga	LSK 1K5	51,536.00	Square feet	80	No	0	454,825.36670	kWh	30,072.64929	Cubic Meter	64,724	15.03	A water source heat pump system, approx. 80% school area.
St. Francis Xavier Elementary (Replacement)	School	111 Bartley Bull Paerkeyway	Brampton	L6W 2J8	43,196.09	Square feet	80	No	3	358,058.83105	kWh	24,820.66416	Cubic Meter	53,120	14.40	A water source heat pump system, approx. 80% school area.
St. Francis Xavier SS	School	50 Bristol Road West	Mississauga	LSR 3K3	218,528.30	Square feet	80	No	17	2,168,216.50391	kWh	162,910.66729	Cubic Meter	345,509	17.84	A water source heat pump system, approx. 80% school area.
St. Gabriel Adult Learning Centre	School	370 Brandon Gate Drive	Mississauga	L4T 3M8	26,403.87	Square feet	80	No	0	276,466.76074	kWh	61,051.91914	Cubic Meter	120,209	35.04	
St. Gerard Sep S	School	1300 McBride Avenue	Mississauga	L5C 1M8	40,849.04	Square feet	80	No	0	212,925.91833	kWh	37,471.75560	Cubic Meter	74,528	14.96	
St. Gertrude Sep S - Closed, 09/2017	School	815 Ceremonial Drive	Mississauga	LSR 3S2	69,502.57	Square feet	80	No	0	214,442.68896	kWh	54,598.92244	Cubic Meter	106,936	11.43	
St. Gregory	School	1075 Swinboun Drive	Mississauga	LSV 1B9	57,933.00	Square feet	80	No	2	522,774.94995	kWh	57,365.07187	Cubic Meter	117,499	19.55	
St. Helen Sep S	School	1325 Brodley Road	Mississauga	LSJ 3X1	38,125.77	Square feet	80	No	0	151,555.90503	kWh	52,498.15787	Cubic Meter	101,876	18.61	
St. Herbert	School	5180 Fallingbrook Drive	Mississauga	LSV 2C6	60,428.59	Square feet	80	No	0	657,940.85840	kWh	66,839.28754	Cubic Meter	137,749	22.64	
St. Hilary E S	School	5070 Fairwind Drive	Mississauga	LSR 2N4	55,000.00	Square feet	80	No	0	389,851.75684	kWh	59,307.72552	Cubic Meter	118,872	18.55	
St. Isaac Jogues	School	300 Great Lakes	Brampton	LSR 2W7	58,512.62	Square feet	80	No	0	500,999.00000	kWh	31,153.24010	Cubic Meter	67,565	14.22	A water source heat pump system, approx. 80% school area.
St. James Sep S	School	98 Wanita Road	Mississauga	LSG 1B8	30,967.77	Square feet	80	No	0	176,635.43359	kWh	40,054.40469	Cubic Meter	78,783	19.45	
St. Jean Brebeuf Sep S	School	63 Glenforest Road	Brampton	L6S 1L8	37,952.40	Square feet	80	No	14	224,218.99847	kWh	54,652.70125	Cubic Meter	107,206	21.21	
St. Jean-Marie Vianney CES	School	75 Jordensen Drive	Brampton	L6X 0S1	59,026.00	Square feet	80	No	2	360,491.00000	kWh	24,758.45701	Cubic Meter	53,045	10.57	A water source heat pump system, approx. 80% school area.
St. Jerome Sep S	School	790 Paisley Boulevard West	Mississauga	L5C 3P5	35,263.62	Square feet	80	No	6	259,750.86304	kWh	27,858.43474	Cubic Meter	57,163	15.76	
St. Joachim Sep S	School	435 Rutherford Drive North	Brampton	L6V 3V9	64,073.17	Square feet	80	No	16	312,707.90771	kWh	56,553.37353	Cubic Meter	112,331	14.26	
St. Joan of Arc SS	School	3801 Thomas Street	Mississauga	LSM 7G2	183,871.00	Square feet	80	No	4	2,072,404.00000	kWh	96,965.00000	Cubic Meter	219,173	16.88	1. A water source heat pump system, approx. 80% school area. 2. The building also contains a public library.
St. John Bosco S	School	1025 North Park Drive	Brampton	L6S 4E1	61,205.69	Square feet	80	No	12	531,461.00000	kWh	835.23813	Cubic Meter	10,772	8.83	Electric Heating
St. John Fisher Sep S	School	330 Balmoral Drive	Brampton	L6T 1V6	38,783.94	Square feet	80	No	9	382,865.99860	kWh	46,122.95665	Cubic Meter	93,824	22.51	
St. John of the Cross	School	3180 Aquitaine Avenue	Mississauga	LSN 3S5	39,236.78	Square feet	80	No	0	369,744.97687	kWh	19,057.61021	Cubic Meter	42,427	14.59	
St. John Paul II Sep S	School	9094 Bolton Heights Road	Bolton	L7E 5R8	75,853.00	Square feet	80	No	6	439,829.18488	kWh	76,777.26639	Cubic Meter	152,765	16.56	Water-source heat pump, approx. 60% school areas.
St. John the Baptist	School	299 Landsbridge Street	Bolton	L7E 2K4	69,072.02	Square feet	80	No	0	384,560.42578	kWh	47,951.80220	Cubic Meter	97,311	12.95	
St. John XXIII Sep S	School	915 McBride Avenue	Mississauga	L5C 1M1	44,463.52	Square feet	80	No	8	206,451.38849	kWh	65,802.03537	Cubic Meter	127,978	20.37	
St. Joseph ES (Brampton)	School	8 Parkway Avenue	Brampton	L6X 2G4	23,537.43	Square feet	80	No	2	126,053.87038	kWh	57,908.14697	Cubic Meter	111,663	31.50	
St. Joseph Sep S (Mississauga)	School	249 Church Street	Mississauga	LSM 1N1	45,406.00	Square feet	80	No	1	261,736.26562	kWh	35,199.47100	Cubic Meter	71,077	14.00	
St. Joseph SS	School	5555 Creditview Raod	Mississauga	LSV 2B9	193,113.10	Square feet	80	No	8	1,982,630.74805	kWh	81,967.15566	Cubic Meter	189,265	14.78	Ground Source Heat Pump system, serving approx. 80% school area
St. Josephine Bahkita Catholic Elementary School	School	430 Van Kirk Drive	Brampton	L7A 0J2	53,304.00	Square feet	80	No	10	584,800.00000	kWh	32,035.54604	Cubic Meter	70,683	17.36	A water source heat pump system, approx. 80% school area.
St. Jude Sep S	School	175 Nahani Way	Mississauga	L4Z 3J6	62,278.84	Square feet	80	No	14	421,920.31641	kWh	72,227.70770	Cubic Meter	143,854	19.10	

St. Julia	School	6770 Historic Trail	Mississauga	LSW 1J3	58,841.00	Square feet	80	No	1	420,449.84277	kWh	40,709.50818	Cubic Meter	84,239	14.50	
St. Kateri Tekakwitha	School	3566 South Common Court	Mississauga	LSL 2B1	133,558.60	Square feet	80	No	0	891,803.19189	kWh	115,403.23608	Cubic Meter	233,611	15.86	A 200 ton "McQuay" chiller
St. Kevin Sep S	School	103 Malta Avenue	Brampton	L6Y 4C8	56,575.11	Square feet	80	No	0	394,651.99768	kWh	77,180.43199	Cubic Meter	152,746	21.47	
St. Leonard Sep S	School	185 Conestoga Drive	Brampton	L6Z 2Z7	52,108.09	Square feet	80	No	0	328,118.00000	kWh	61,402.42316	Cubic Meter	121,765	18.82	
St. Louis Sep S	School	1450 Lewisham Drive	Mississauga	LSJ 3R3	33,895.55	Square feet	80	No	0	128,557.30188	kWh	60,115.13083	Cubic Meter	115,879	22.64	
St. Lucy Catholic	School	25 Kanata Road	Brampton	L7A 3R2	52,517.12	Square feet	80	No	0	421,603.00000	kWh	31,216.62323	Cubic Meter	66,312	14.35	A water source heat pump system, approx. 80% school area.
St. Luke Elementary School	School	1280 Colbalt Street	Mississauga	LSH 4L8	55,563.30	Square feet	80	No	0	444,688.33325	kWh	50,096.59775	Cubic Meter	102,406	17.59	A water source heat pump system, approx. 80% school area.
St. Marcellinus Secondary School	School	730 Courtney Park Drive West	Mississauga	LSW 1L9	195,098.00	Square feet	80	No	6	2,502,276.00000	kWh	145,689.00000	Cubic Meter	318,728	20.76	A water source heat pump system, approx. 80% school area.
St. Margaret of Scotland	School	2266 Council Ring Road	Mississauga	LSL 1C1	59,642.83	Square feet	80	No	0	457,582.63403	kWh	67,639.59232	Cubic Meter	135,797	19.72	
St. Marguerite Bourgeoys Sep S	School	550 North Park Avenue	Brampton	L6S 4J8	34,893.36	Square feet	80	No	2	226,816.99969	kWh	37,446.49192	Cubic Meter	74,721	17.91	
St. Marguerite d'Youville SS	School	10815 Dixie Road	Brampton	L6R 2W5	205,309.20	Square feet	80	No	11	1,706,764.00000	kWh	73,880.60488	Cubic Meter	169,204	12.14	A water source heat pump system, approx. 80% school area.
St. Maria Goretti E S	School	121 Royal Orchard Drive	Brampton	L6X 4K9	51,843.28	Square feet	80	No	4	290,542.99854	kWh	32,597.22463	Cubic Meter	66,655	12.29	
St. Mark Sep S	School	3675 Sawmill Valley Drive	Mississauga	LSL 2Z5	46,144.88	Square feet	80	No	0	197,418.21106	kWh	40,740.96328	Cubic Meter	80,441	13.66	
St. Martin Sep S	School	2470 Rosemary Drive	Mississauga	L5C 1X2	126,475.90	Square feet	80	No	0	891,776.77539	kWh	66,973.95795	Cubic Meter	142,049	12.68	A water source heat pump system, approx. 80% school area.
St. Mary Sep S (Brampton)	School	66 Main Street South	Brampton	L6W 2C6	30,093.18	Square feet	80	No	5	227,330.01855	kWh	66,676.07403	Cubic Meter	129,992	31.10	
St. Matthew Sep S	School	280 Kingsbridge Garden Circle	Mississauga	LSR 1L3	42,183.77	Square feet	80	No	0	341,802.76709	kWh	53,264.40212	Cubic Meter	106,616	21.52	
St. Michael SS	School	9130 Columbia Way	Bolton	L7E 4G6	168,745.80	Square feet	80	No	0	1,277,215.65234	kWh	113,903.87852	Cubic Meter	237,443	14.74	A water source heat pump system, approx. 80% school area.
St. Monica ES	School	60 Sterritt Drive	Brampton	L6Y 5B6	54,014.35	Square feet	80	No	6	339,641.00000	kWh	40,382.76693	Cubic Meter	82,224	14.23	
St. Nicholas Elementary School	School	120 Harvest Moon Drive	Bolton	L7E 2W1	71,093.00	Square feet	80	No	2	532,463.99829	kWh	20,010.19845	Cubic Meter	47,042	10.48	A water source heat pump system (original school only), approx. 60% school area.
St. Patrick Sep S	School	11948 The Gore Road	Brampton	L6P 0A2	36,425.07	Square feet	80	No	0	227,305.99966	kWh	60,379.47429	Cubic Meter	118,087	23.86	
St. Paul S S	School	815 Atwater Avenue	Mississauga	LSF 1L8	107,445.40	Square feet	80	No	0	915,883.46875	kWh	92,968.61776	Cubic Meter	191,612	17.72	A water source heat pump system, approx. 80% school area.
St. Peter Sep S	School	46 Dawson Road	Orangeville	L9W 2W3	34,015.00	Square feet	80	No	0	228,150.96658	kWh	55,893.41602	Cubic Meter	109,620	24.17	
St. Philip Sep S	School	345 Fairview Road West	Mississauga	L5B 3W5	55,714.00	Square feet	80	No	0	423,985.93848	kWh	56,194.12821	Cubic Meter	113,576	18.33	
St. Pio of Pietrelcina	School	4765 Huron Heights Drive	Mississauga	L4Z 4G9	62,064.71	Square feet	80	No	0	535,025.90625	kWh	64,378.11865	Cubic Meter	130,970	19.64	
St. Raphael Sep S	School	3470 Clara Drive	Mississauga	L4T 2C7	45,003.91	Square feet	80	No	0	260,082.84302	kWh	51,933.77744	Cubic Meter	102,686	18.04	
St. Raymond	School	5735 Whitehorn Avenue	Mississauga	LSV 2A9	54,486.91	Square feet	80	No	0	515,905.15527	kWh	31,410.45324	Cubic Meter	68,310	15.60	A water source heat pump system, approx. 80% school area.
St. Richard Sep S	School	7270 Copenhagen Road	Mississauga	LSN 2C3	41,888.00	Square feet	80	No	0	237,184.78094	kWh	52,802.72573	Cubic Meter	103,933	19.06	
St. Rita	School	30 Summer Valley Drive	Brampton	L6Z 4V6	65,208.82	Square feet	80	No	6	706,174.00000	kWh	46,786.99851	Cubic Meter	100,672	18.45	A water source heat pump system, approx. 80% school area.
St. Roch Catholic SS	School	200 Valleyway Dr	Brampton	L6X 0N3	174,849.00	Square feet	80	No	0	1,752,320.00000	kWh	8,722.08920	Cubic Meter	46,802	10.55	A water source heat pump system, approx. 80% school area.
St. Rose of Lima Sep S	School	4590 The Gallops	Mississauga	LSM 2W4	31,488.72	Square feet	80	No	4	500,517.12830	kWh			8,658	15.90	100% electric heating

St. Sebastian	School	3460 Aquinas Avenue	Mississauga	LSM 7L2	54,296.00	Square feet	80	No	0	568,538.10034	kWh	56,127.06518	Cubic Meter	115,950	21.46	A water source heat pump system, approx. 80% school area.
St. Simon Stock	School	6440 Lisgar Drive	Mississauga	LSN 6K3	51,074.75	Square feet	80	No	0	583,674.82751	kWh	58,187.88785	Cubic Meter	120,108	23.54	A water source heat pump system, approx. 80% school area.
St. Sofia Sep 5	School	3540 Havenwood Drive	Mississauga	L4X 2M9	49,699.00	Square feet	80	No	1	279,455.52637	kWh	40,484.90443	Cubic Meter	81,376	14.28	
St. Stephen Sep 5	School	17 Colonel Bertram Road	Brampton	L6Z 4N8	39,687.06	Square feet	80	No	3	669,403.00000	kWh			11,579	16.87	100% electric heating
St. Teresa of Avila Sep 5	School	6675 Montevideo Road	Mississauga	LSN 4E8	46,525.00	Square feet	80	No	0	432,060.06641	kWh	57,160.23371	Cubic Meter	115,542	22.34	
St. Therese of the Child Jesus E 5	School	6930 Forest Park Drive	Mississauga	LSN 6X7	57,899.07	Square feet	80	No	0	389,754.29517	kWh	50,197.67414	Cubic Meter	101,647	15.95	
St. Thomas Aquinas Sep 5	School	25 Corporation Drive	Brampton	L6S 6A2	231,775.90	Square feet	80	No	22	2,161,624.00000	kWh	143,314.74228	Cubic Meter	308,346	15.90	A water source heat pump system for 2002 Addition, approx. 15% school area; a heat recovery "Trane" chiller for the original school, 85% area.
St. Thomas More Sep 5	School	3270 Tomken Road	Mississauga	L4Y 2Y7	57,554.63	Square feet	80	No	0	353,846.87793	kWh	114,829.92887	Cubic Meter	223,221	27.35	
St. Timothy (Replacement)	School	2214 Cliff Road	Mississauga	LSA 2N9	47,753.00	Square feet	80	No	6	515,005.34863	kWh	35,729.40746	Cubic Meter	76,460	18.74	A water source heat pump system, approx. 80% school area.
St. Ursula	School	11 Dwellers Road	Brampton	L6X 5C1	62,452.21	Square feet	80	No	0	576,700.00000	kWh	51,892.93701	Cubic Meter	108,086	18.07	A water source heat pump system, approx. 80% school area.
St. Valentine Elementary School	School	5610 Heatherleigh Avenue	Mississauga	LSV 2V7	56,564.87	Square feet	80	No	3	520,193.83984	kWh	47,407.83246	Cubic Meter	98,629	18.10	A water source heat pump system, approx. 80% school area.
St. Veronica Elementary School	School	680 Novo Star Drive	Mississauga	L5W 1C7	58,426.50	Square feet	80	No	0	452,234.80591	kWh	43,861.81917	Cubic Meter	90,749	15.72	A water source heat pump system, approx. 80% school area.
St. Vincent de Paul Sep 5	School	665 Willowbank Trail	Mississauga	L4W 3L6	37,372.30	Square feet	80	No	0	240,141.92090	kWh	28,964.82362	Cubic Meter	58,916	14.66	
Sts. Martha & Mary Sep 5	School	1760 Bough Beeches Boulevard	Mississauga	L4W 2B9	40,020.22	Square feet	80	No	0	314,986.58447	kWh	36,153.93477	Cubic Meter	73,802	17.47	
Sts. Peter & Paul Sep 5	School	4205 Woodington Drive	Mississauga	L4Z 1K2	33,260.48	Square feet	80	No	0	191,262.35303	kWh	24,741.97411	Cubic Meter	50,086	13.66	
Venerable Michael J. McGivney	School	450 Fernforest Drive	Brampton	L6R 2P7	54,892.70	Square feet	80	No	2	441,651.00000	kWh	46,452.14491	Cubic Meter	95,463	17.04	A water source heat pump system, approx. 80% school area.